

OFFICE OF CIVIL SURGEON, SIRSA  
NO-OBJECTION CERTIFICATE

No. ME/2025/77

Dated – 05/09/2025

It is Certified Rajendra Public Sr Sec. School, Panjuwana la Disst. Sirsa which is run by Rajendra Education Society, Sirsa Was inspected by Medical Officer i/C CHC Baragudha & PHC Bansudhar, Sirsa on dated 13/08/2025 & reported that hygiene & sanitation of this school is satisfactory. The structure of this school is well ventilated. Facility of Potable Water is available with R.O. First Aid and separate toilets for Male & female are available. No smoking signage is displayed at prominent place. Nobody was found to be selling Tobacco Products with in 200mtr area of school boundary. Total climate of this school is neat and clean. Health Department has no objection regarding this. School Well Corporate in Various National Health Programmes Implemented in Schools.

This certificate is to be reviewed after one year.

Dy. Civil Surgeon (M)  
For Civil Surgeon, Sirsa.

5.9.25

Counter Sign.



Civil Surgeon  
Sirsa, SA

Memo No:- 495

Date:- 25/03/2026

Certificate  
No: TC-11949

**Subject : Physical / Chemical Examination Report of Water Sample**

Sample ID/Classification : SIR/05802/3/2026 / Private	<b>Sample Details</b>	<b>Date &amp; Time</b>
Sender : Rajendra public sr sec school sirsa	Collected By	naresh
Location : , R o water Rajendra public sr sec school sirsa	Collection Date	24/03/2026 at 15:16
Sample Description : Drinking Water	Received at lab	24/03/2026 at 15:50
Latitude / Longitude : 74.981787 / 29.629570	Analysis Start Date	24/03/2026
	Analysis End Date	25/03/2026
	Sample Quantity	1 ltr

**Test Result (As Per BIS 10500 :2012)**

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	BDL	1 NTU	5 NTU	APHA 24th Edition -2130 B
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):1984: RA:2002
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5):1983: RA:2002
4	Color	BDL	5 Hazen Units	15 Hazen Units	APHA24th Edition 2120 B
5	Total Dissolved Solids @ 180°C ± 2°C	142	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C
6	Total Hardness as CaCo3	50	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C
7	Calcium as Ca	8.01	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B
8	Magnesium as Mg	7.29	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg B
9	Total Alkalinity	60	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B
10	Chloride as Cl	22.99	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B
11	Sulphate as So4	34.7	200 mg/lit.	400 mg/lit.	USEPA
12	Fluoride as F	0.120	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition 4500 F-D:
13	Iron as Fe	BDL	1.0 mg/lit.	1.0 mg/lit.	USEPA
14	Nitrate as No3	1.12	45 mg/lit.	45 mg/lit.	APHA 4500-NO3- B
15	pH @ 25°C	7.12	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B
16	Free Residual Chlorine	0.0	0.2 mg/lit.	1.0 mg/lit.	IS 3025 (Part-26):2021

**Remarks :-**

- \* The Results Given above are related to the sample as received and tested in PHED Lab.
- \* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- \* The test report can't be used for any publicity or any legal purpose.
- \* Reliability of water sample sample lies with sender/collector of water sample.
- \* To check the sample report online Scan the QR Code below.
- \* The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.



Sample analyzed by :

SANTOSH KUMARI , SENIOR CHEMIST  
ZONAL WATER TESTING LABORATORY,  
email:-Seniorchemist.hr@phedharyana.gov.in